



CHIODINI ASSOCIATES Architecture/Interior  
Design/Graphics

**ADDENDUM NUMBER FIVE – Fire Marshal Comments**

**DATE:** June 28, 2016

**TO CONTRACT DOCUMENTS ENTITLED:**

**CITY OF LADUE  
FIRE COMPANY NO. 1**  
9213 Clayton Rd.  
Ladue, MO 63124

**PROJECT NUMBER:**

Chiodini Associates Project No. 2010.100.03

**ARCHITECT:**

Chiodini Associates  
1401 S. Brentwood Blvd. Suite # 425  
St. Louis, Missouri 63144  
(314) 725-5588 (PHONE) (314) 725-4347 (FAX)

Drawings and Specifications for the above noted project and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

**CHANGES IN SPECIFICATIONS:**

**CHANGES TO DRAWINGS:**

Sheet A002/Sheet A101 Add Fire extinguisher cabinet in basement.

Dwg P001

- Plumbing fixture SH-1 revised to show the following: Kohler Choreograph 60"x32"x96" Wall kit with a Bellwether Shower Base K-9165 and a Choreograph 7" Floating shelf K-97621. Provide Symons ADA Model S1-100-X pressure balanced shower valve with integral stops. Provide with a grid drain."

Dwg E301

- Add (2) fire alarm smoke detectors: (1) in Mechanical Room #003 and (1) in Workout Room #002.
- Add (1) fire alarm smoke detector above Fire Alarm Control Panel (FACP) in Stair #400F.

Dwg E302

- Add (1) manual pull station within 10 ft. of hood for hood suppression system. Manual pull provided with hood. Hood shall be tied into fire alarm system.

**END OF ADDENDUM NUMBER FIVE**

X:\2010.100.03 – City of Ladue – Municipal Fire Facilities\Project\Bidding-Estimates-Addenda

**CHIODINI ASSOCIATES Architecture/Interior Design/Graphics**  
1401 South Brentwood Blvd., Suite 425 St. Louis, Missouri 63144  
(314)725-5588 (314) 725-4347 (fax) e-mail: arch@chiodini.com