



**REQUEST FOR INFORMATION #5**

Date: 6/13/16

**RFI Subject: Electrical, Flooring and Flagpole**

Project: City of Ladue Fire House #1

Reference Drawings/Specifications: \_\_\_\_\_

Question Author: Katie Hoffman

Question:

Electrical:

1. Drawing E301, note 4, where is the relay located?
2. Drawing E301, note 4, can you specify the digital timer switch?

Flooring:

1. Please provide specifications for the Johnsonite Rubber Tile AND Stair Treads (only color was specified).
2. Do we need to include stringers?

Flagpole:

1. Please provide the height of the slide pole on the above project.

Answer Company: Chiodini Architects

Answer Requested By: June 17, 2016

Answer:

Electrical:

1. Relay located at southeast corner of Apparatus Bay (where keynote 4 is pointing). Coordinate with owner's vendor.
2. No digital timer switch. Revise keynote 4 to read: "Provide (2)#12, (1)#12G., in 1"C. from new relay to existing emergency signaling fixture. Provide signal cable routed to fire station controller at IT closet. Coordinate with owner's vendor for connection requirements.

Answer By: Randy Buechele (Electrical)

Answer Date: June 15, 2016